

Ordering code DMP 334

31.5.2016

DMP 334

Pressure transmitter (0 ... 600 / 2200 bar)



Pressure	
gauge	1 4 0
Input [bar]	
600	6 0 0 3
1000	1 0 0 4
1600	1 6 0 4
2000	2 0 0 4
2200	2 2 0 4
Customer	9 9 9 9
Output	
4 ... 20 mA / 2 wire	1
0 ... 20 mA / 3 wire	2
0 ... 10 V / 3 wire	3
Intrinsic safety Ex ia 4 ... 20 mA / 2 wire	E
Customer	9
Accuracy	
0,35% (standard)	3
0,35% calibration including certificate	S
Measured values table for accuracy 0,35% (only on customer request)	M
Customer	9
Electrical connection	
Connector DIN 43650 (ISO 4400) (IP 65)	1 0 0
Connector Binder Serie 723 5-pin (IP 67)	2 0 0
Cable gland PG7 / cable length specify (IP 67)	4 0 0
+ PVC cable / 1 m	
Connector Buccaneer (IP 68)	5 0 0
Field housing stainless steel (IP 67)	8 0 0
Increase of coverage for IP 67 (for connector DIN 43650) (ISO 4400)	E 0 0
M 12 x 1 (4-pin) (Binder 713) (IP 67)	M 0 0
Customer	9 9 9
Mechanical connection	
G 1/2" EN 837-1/-3 (max pressure 1600 bar)	2 0 0
M20x1.5 internal thread	D 2 8
9/16 UNF internal thread	V 0 0
Customer	9 9 9
Seals	
Without seals - welded	2
Customer	9
Special version	
Standard	0 0 0
Customer	9 9 9

0,...without additional charge

On request (OR)...in accordance with the producer

Standard EN 837-1/-3 corresponds to original Standard DIN 16288

Additional charge for calibration is not subject to reduction.

This data sheet contains product specification; properties are not guaranteed.

Subject to change without notice.

This dokument contains product specification; properties are not guaranteed. Detailed information about options are defined in the datasheet. Subject to change without notice.



BD SENSORS s.r.o.
Hradištská 817
CZ – 687 08 Buchlovce

Tel.: +420 572 411 011
Fax: +420 572 411 497

www.bdsensors.cz
info@bdsensors.cz

The company BD SENSORS s.r.o. is certified by TÜV SÜD Czech according to the standard ISO 9001.

