


Ordering code OEM 18.600G

31.5.2016

OEM 18.600G



Pressure transmitter (0 ... 0,1 / 6 bar)

Pressure [bar]

0 ... 0,1	1	0	0	0
0 ... 0,25	2	5	0	0
0 ... 0,4	4	0	0	0
0 ... 0,6	6	0	0	0
0 ... 1	1	0	0	1
0 ... 1,6	1	6	0	1
0 ... 2,5	2	5	0	1
0 ... 4	4	0	0	1
0 ... 6	6	0	0	1
-1...0	X	1	0	2
Customer - underpressure (accuracy 1%)	9	9	9	9

Input [bar]

Gauge R

Output

4 ... 20 mA / 2-wire	1
0 ... 10 V / 3 wire	3
10 ... 90% of V_s / 3-wire ratiometric ($V_s = 2,7 \dots 5$ VDC)	R
Customer	9

Accuracy

0,50%	5
0,5 % calibration including certificate	T
Customer	N
	9

Electrical connection

Connector DIN 43650 (ISO 4400) (IP 65)	1	0	0
	4	0	0
	C	1	0
	E	0	0
M 12 x 1 (4-pin) (Binder 713) (IP 67)	M	0	0
Cable outlet / cable length specify (IP 68)	T	A	0
+ PVC cable / 1 m			
Customer	9	9	9

Mechanical connection

G 1/4" DIN 3852 (only with seals "P")	3	0	0
G 1/4" EN 837-1/-3 (manometric)	4	0	0
1/4" NPT	N	4	0
Customer	9	9	9

Seals

Viton (FKM)	1
Customer	9

Special version

Standard	0	0	0
Customer	9	9	9

0,-...without additional charge

On request... in accordance with the producer

Standart EN 837-1/-3 corresponds to original Standart DIN 16288

Additional charge for calibration and temperature compensation are not subject to reduction.

This data sheet contains product specification; properties are not guaranteed.

Subject to change without notice.



BD SENSORS s.r.o.
Hradištská 817
CZ – 687 08 Buchlovice

Tel.: +420 572 411 011
Fax: +420 572 411 497

www.bdsensors.cz
info@bdsensors.cz



The company BD SENSORS s.r.o. is certified by TÜV SÜD Czech according to the standard ISO 9001.