

Certificate of compliance

Product



Holder BD Sensors, Germany

Compliant Item LMK 307

Basis of Certification IEC 61508:2010

IEC 61511:2016

Certification Include(s) ✓ Hardware requirements

☑ Reliability requirements

☑ Basic safety

☑ User documentation

Functional Safety Data

Safety function: See report

Mode: Low demand

Type: A

HFT: 0

Hardware compliance route: 2_H Systematic compliance route: 2_S

Failure rates (FIT): DU = 352 FIT (See report)

Fit for use up to: SIL 2 (HFT=0) SIL 3 (HFT=1)

Certification Results Risknowlogy certifies that the above Compliant Item

meets the requirements of the Basis of Certification for the selected assessment(s). The Risknowlogy report

49.532.6 is an integral part of this certificate.

Certificate Number 49.532.12-0

Initial Certification 2007-02-15

This Certificate 2022-08-18

Expiry Date 2027-08-18

Certifier Dr. Michel Houtermans



